

**State Load Despatch Center,Airoli (MSETCL) Statement I**  
**Daily system Report for 07/Apr/2020 TUESDAY**

I GENERATION (MUS)		II EXCHANGES (MUS)	
A) MSPGCL	Daily	Monthly	E) InterState Exchanges
			Daily
1) Thermal	45.897	395.707	1) Gujrat
2) Hydro	23.232	123.292	
3) Gas	6.917	50.949	2) Madhya Pradesh
<b>Total MSPGCL</b>	<b>76.046</b>	<b>569.948</b>	3) Chattisgarh
<b>B) 1) APML</b>	58.241	380.941	4) Maharashtra
2) JSWEL	13.643	81.936	5) Goa (Arona)
3) VIPL	0.000	0.000	<b>Total</b>
4) RPL(AMT)	0.000	0.000	<b>163.432</b>
5) WPCL	5.681	38.898	a) Mumbai Schedule
6) Other IPP	8.081	55.391	b) Mumbai Drawl
7) PGPL	0.000	0.000	c) MSEDCL Bilateral *
<b>C) 1) TPCL Thermal</b>	16.094	100.903	Include PX
2) TPCL Hydro	1.737	17.354	d) Mumbai Bilateral *
3) TPCL Gas	2.515	17.827	Include PX
4) AEML Thermal	11.743	77.980	Standby
<b>D) STATE</b>			<b>H) ENERGY CATERED (MUS)</b>
1) Thermal	159.380	1131.756	1) MSEDCL
(A1+C1+C4+(B1+B6))			2) Mumbai Discoms
2) Hydro	24.969	140.646	<b>TOTAL STATE</b>
(A2+C2)			<b>217.720</b>
3) Gas	9.432	68.776	<b>1476.248</b>
(A3+B7+C3)			
4) Wind	16.371	83.625	
	7.568	51.445	
6) SOLAR			
<b>TOTAL STATE</b>	<b>217.720</b>	<b>1476.248</b>	<b>381.152</b>

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs		B. Day Peak at 13 Hrs		C. Evening Peak at 20 Hrs		D. Night Minimum at 23 Hrs
	12 Hrs	18 Hrs	13 Hrs	20 Hrs	20 Hrs	23 Hrs	
MSPGCL Thermal	1876		1939		2060		2036
MSPGCL Hydro	1070		399		605		364
MSPGCL Gas	283		271		288		292
MSPGCL Total Generation	3229		2609		2953		2692
Central Sector Receipt	8010		8462		5412		6049
WIND	269		430		1194		991
CPP / IPP Thermal	3461		3529		3628		3630
CPP / IPP Gas	0		0		0		0
SOLAR	1013		1015		0		0
Exchange with Mumbai	-386		-444		-606		-559
<b>MSEDCL DEMAND MET</b>	<b>15596</b>		<b>15601</b>		<b>12581</b>		<b>12803</b>
Load Shedding	0		0		0		0
MSEDCL DEMAND	15596		15601		12581		12803
TPCL GENERATION	951		914		785		907
AEML GENERATION	497		499		438		500
<b>MUMBAI DEMAND</b>	<b>1834</b>		<b>1857</b>		<b>1829</b>		<b>1966</b>
STATE DEMAND MET	17430		17458		14410		14769
<b>STATE DEMAND</b>	<b>17430</b>		<b>17458</b>		<b>14410</b>		<b>14769</b>
Frequency (Hz)	50.01		49.99		50.04		50.03

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 18.01 Hrs	49.83 Hz at 00.07 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge